

**Second Annual Conference on Carbon Sequestration
Washington, May 5-8, 2003**

**Co-production of Hydrogen, Electricity
and CO₂ from Coal using
Commercially-Ready Technology**

**Paolo Chiesa*, Stefano Consonni*§
Thomas G. Kreutz§, Robert H. Williams§**

*** Politecnico di Milano**

§ Princeton University

Large Scale Production of H₂ from Fossil Fuels

Four Related Papers Prepared Under Princeton University's Carbon Mitigation Initiative Presented Here

| | Natural Gas | Coal & Residuals |
|-------------------------|--|---|
| CO ₂ Venting | Almost all H ₂ produced today | Refineries, chemicals, NH ₃ production in China 2) “Conventional technology” |
| CO ₂ Capture | 1) FTR vs. ATR with CC | 2) “Conventional technology” 3) Membrane reactors 4) Overview |

Motivation

- ◆ **With respect to conventional Steam Cycles (SC), IGCC allow generating electricity from coal with:**
 - **higher efficiency**
 - **lower environmental impact**
 - **comparable costs**
- ◆ **Efficiency and cost penalties due to carbon capture are much lower for oxygen-blown IGCC than for SC**
- ◆ **Oxygen-blown IGCC with pre-combustion carbon capture produces fuel gas with ~93% H₂ by volume**
- ◆ **An oxygen-blown IGCC with carbon capture can co-produce pure hydrogen with minimal modifications and very limited additional costs**

Purpose of this study

- ◆ Understand thermodynamic and technological issues
- ◆ Assess performances and costs achievable with commercially available technologies
- ◆ Understand trade-offs among hydrogen, electricity and CO₂ production
- ◆ Understand benefits/caveats of alternative configurations
- ◆ Build a reference for comparisons with alternative feedstocks (particularly nat gas) and advanced technologies (including membranes)

Basic Assumptions


- ◆ **Large scale plants: coal input 900-1800 MW (LHV), 1-2 large gasification trains**
- ◆ **Stand-alone plants: no steam or chemical integration with adjoining process**
- ◆ **Texaco gasifier at 70 bar with (i) quench or (ii) radiative + convective syngas cooler**
- ◆ **Current “F” gas turbine technology: Siemens V94.3a for plants producing mainly electricity, Siemens V64.3a for plants producing mainly hydrogen**
- ◆ **CO₂ venting vs CO₂ capture by physical absorption (Selexol)**
- ◆ **Pure H₂ separated by Pressure Swing Absorption (PSA)**

Plant configurations

- ◆ 1) Production of Electricity vs H₂
- ◆ 2) CO₂ venting vs CO₂ capture
- ◆ 3) Quench vs Syngas cooler

| Power Cycle | Main Output | CO ₂ venting | | CO ₂ capture | |
|----------------|-------------|---------------------------------------|---------------|--|--|
| | | quench | syngas cooler | quench | syngas cooler |
| Combined Cycle | Electricity | 1 case | 1 case | 1 case | 1 case |
| | Hydrogen | 1 case | 1 case | investigate: a) gasif pressure b) H ₂ S+CO ₂ co-capture c) H ₂ purity d) E/H ₂ ratio | investigate: a) steam/carbon b) E/H ₂ ratio |
| Steam Cycle | Hydrogen | assess performances and costs vs IGCC | | assess performances and costs vs IGCC | |


Basic system design




More Basic Assumptions

- ◆ 95% pure O₂ compressed at 84 bar. N₂ compressed to gas turbine combustor for NO_x control ($T_{stoich} \leq 2300$ K)
- ◆ Sulfur removal by physical absorption (Selexol) with steam stripping + Claus plant + SCOT unit
- ◆ Tight integration with steam cycle with 4 pressure levels. Evaporation at 165, 15, 4 bar; Reheat at 36 bar. Superheat and Reheat at 565°C
- ◆ With CO₂ capture, HT shift at 400-450°C + LT shift at 200-250°C. Both ahead of sulfur removal.
- ◆ Air flow to gas turbine adjusted to keep same pressure ratio of nat gas-fired version
- ◆ CO₂ released in 3 flash tanks at decreasing pressure to minimize compression work (+ 1 HP flash and recycle compressor to minimize H₂ co-capture)

Electricity-Pure CO₂ capture-Quench



Hydrogen-Pure CO2 capture-Quench



Heat and Mass Balances

- ◆ **Code developed at Politecnico di Milano and Princeton to predict the performances of power cycles, including:**
 - ↗ **chemical reactions (→ gasification, steam reforming)**
 - ↗ **heat/mass transfer (→ saturation)**
 - ↗ **some distillation process (→ cryogenic Air Separation)**
- ◆ **Model accounts for most relevant factors affecting cycle performance:**
 - ↗ **scale**
 - ↗ **gas turbine cooling**
 - ↗ **turbomachinery similarity parameters**
 - ↗ **chemical conversion efficiencies**
- ◆ **Accuracy of performance estimates has been verified for a number of state-of-the-art technologies**

Capital Cost Estimate

$$\text{Cost (M\$)} = n \cdot C_0 \cdot [S / (n \cdot S_0)]^f$$

| Component | Scaling parameter | Cost model | Base cost C0 M\$ | Base Size S0 | scale factor f | # of Trains n |
|------------------------------------|-------------------------------|-------------------|-------------------------|---------------------|-----------------------|----------------------|
| Coal stoarge, prep, handling | Raw coal feed (mt/day) | Holt-e | 29.1 | 2367 | 0.67 | 2/1 |
| Air separation unit | Pure O2 input (mt/day) | Holt-e | 45.7 | 1839 | 0.50 | 2/1 |
| Extra O2 compressor | % of total O2 comp. pwr (MWe) | Lozza | 6.3 | 10.0 | 0.67 | 2/1 |
| N2 compressor (for GT NOx control) | N2 compression power (MWe) | Lozza | 4.7 | 10.0 | 0.67 | 2/1 |
| Gasifier + quench cooling/scrub | Coal input (MWth, HHV) | Holt-e | 61.9 | 716 | 0.67 | 2/1 |
| Gasifier + syngas cooler & scrub | Coal input (MWth, HHV) | Holt-e | 144.3 | 734 | 0.67 | 2/1 |
| WGS reactors, heat exchangers | Coal input (MWth, HHV) | Lozza | 39.8 | 1450 | 0.67 | 2/1 |
| Selexol H2S removal & stripping * | Sulfur flow (mt/day) | Holt-e | 33.6 | 80.7 | 0.67 | 2/1 |
| Sulfur recovery (Claus, SCOT) ** | Sulfur flow (mt/day) | Holt-e | 22.9 | 80.7 | 0.67 | 2/1 |
| Selexol CO2 absorption, stripping | Pure CO2 flow (mt/hr) | Lozza | 32.8 | 327.3 | 0.67 | 2/1 |
| CO2 drying and compression | CO2 compression pwr (MWe) | Jacobs | 14.8 | 13.2 | 0.67 | 2/1 |
| Pressure swing adsorption | Purge gas flow (kmole/s) | Jacobs2 | 7.1 | 0.2942 | 0.74 | 2/1 |
| PSA purge gas compressor | Purge gas comp power (MWe) | Lozza | 6.3 | 10.0 | 0.67 | 2/1 |
| Syngas expander | Syngas expander pwr (MWe) | Lozza | 3.1 | 10.0 | 0.67 | 2/1 |
| Siemens V64.3A gas turbine | Gas turbine power (MWe) | GTW | 30.6 | 67.1 | - | 1/0 |
| Siemens V94.3A gas turbine | Gas turbine power (MWe) | GTW | 74.9 | 265.9 | - | 0/1 |
| GE Frame 7H gas turbine | Gas turbine power (MWe) | GTW | 92.1 | 345.4 | - | 0/1 |
| HRSG and steam turbine | ST gross power (MWe) | Lozza | 94.7 | 200.0 | 0.67 | 1 |
| Power island BOP+electrics | GT+ST gross power (MWe) | Lozza | 57.6 | 450.0 | 0.67 | 1 |

Estimate Cost of Electricity and Cost of H2

| <i>Economic parameters:</i> | |
|---|------|
| Construction interest (% of OC) | 16% |
| Capital charge rate (%/yr) | 15% |
| Capacity factor (%) | 80% |
| O&M costs (% of OC per year) | 4% |
| Coal price (\$/GJ, LHV) | 1.24 |
| CO2 disposal cost (\$/tCO2) | 5.00 |
| Value of Sulfur | 0.00 |
| Extra-cost for CO2+H2S co-sequestration | 0.00 |
| All costs in 2002 US \$ | |

For plants producing H2, value electricity at the cost of the configuration with the same identical features (quench vs syncooler, venting vs capture, etc.)

Plants producing only electricity

| | | no CO2 capture | | CO2 capture | |
|---|------------------------------------|----------------|--------------|--------------|--------------|
| | | quench | syncooler | quench | syncooler |
| % of coal input | Gas turbine | 32.41 | 32.46 | 29.86 | 30.02 |
| | Steam turbine | 19.67 | 23.04 | 18.22 | 20.36 |
| | Syngas expander | 1.04 | 1.08 | 1.00 | 1.02 |
| | ASU and gas compression | -8.41 | -8.12 | -7.64 | -7.53 |
| | Auxiliaries | -1.76 | -1.83 | -1.75 | -1.86 |
| | CO2 removal and compression | 0.00 | 0.00 | -2.91 | -2.89 |
| | Net electric output | 42.95 | 46.63 | 36.79 | 39.12 |
| Total Cost, \$/kWe | | 1395 | 1586 | 1808 | 2038 |
| c/kWh | Capital (15% of TCR) | 2.99 | 3.39 | 3.87 | 4.36 |
| | O&M costs (4% of OC per year) | 0.69 | 0.78 | 0.89 | 1.00 |
| | Fuel (at 1.24 \$/GJ, LHV) | 1.04 | 0.96 | 1.22 | 1.15 |
| | Total electricity cost | 4.72 | 5.14 | 5.98 | 6.51 |
| | CO2 Capture cost, \$/mt CO2 | - | - | 18.53 | 22.27 |
| Extra c/kWh for disposal at 5 \$/mt CO2 | | - | - | 0.40 | 0.38 |

Plants producing mainly hydrogen


| | | no CO2 capture | | CO2 capture | |
|---|---------------------------------------|----------------|--------------|--------------|-------------|
| | | quench | syncooler | quench | syncooler |
| % of coal LHV input | Gas turbine | 4.23 | 4.51 | 4.23 | 4.51 |
| | Steam turbine | 7.49 | 9.38 | 7.49 | 9.38 |
| | Syngas expander | 0.00 | 0.00 | 0.00 | 0.00 |
| | ASU and gas compression | -5.37 | -5.39 | -5.37 | -5.39 |
| | Auxiliaries | -1.32 | -1.49 | -1.36 | -1.49 |
| | CO2 removal and compression | -0.82 | -0.82 | -2.91 | -2.89 |
| | Net electric output | 4.21 | 6.18 | 2.09 | 4.11 |
| Net hydrogen output | 57.46 | 57.45 | 57.46 | 57.45 | |
| Total Cost, \$/kW H2 LHV | | 830 | 1076 | 874 | 1124 |
| \$/GJ LHV | Capital (15% of TCR) | 4.93 | 6.40 | 5.20 | 6.69 |
| | O&M costs (4% of OC per year) | 1.13 | 1.47 | 1.19 | 1.54 |
| | Fuel (at 1.24 \$/GJ, LHV) | 2.17 | 2.17 | 2.17 | 2.17 |
| | Electricity revenue (4.72/6.38 c/kWh) | -0.96 | -1.41 | -0.64 | -1.27 |
| | Total hydrogen cost | 7.28 | 8.63 | 7.92 | 9.12 |
| Extra \$/GJ for disposal at 5 \$/mt CO2 | | - | - | 0.72 | 0.70 |

Other configurations

| | | Base quench, 70 bar S removal 99+ purity max H2 | gasifier at 120 bar | co- capture of H2S and CO2 | fuel-grade purity | increase E/H2 by reducing flow to PSA |
|----------------------------|---|---|------------------------|-------------------------------------|----------------------|---|
| % of coal LHV input | Gas turbine | 4.23 | 4.33 | 4.23 | 3.91 | 22.31 |
| | Steam turbine | 7.49 | 6.62 | 7.49 | 7.25 | 15.03 |
| | Syngas expander | 0.00 | 1.71 | 0.00 | 0.18 | 0.73 |
| | ASU and gas compression | -5.37 | -5.56 | -5.37 | -4.98 | -6.97 |
| | Auxiliaries | -1.36 | -1.40 | -1.36 | -1.40 | -1.64 |
| | CO2 removal and compression | -2.91 | -2.90 | -2.91 | -2.91 | -2.91 |
| | Net electric output | 2.09 | 2.80 | 2.09 | 2.06 | 26.56 |
| Net hydrogen output | 57.46 | 57.28 | 57.46 | 58.17 | 17.25 | |
| Total Cost, \$/kW H2 LHV | | 874 | 885 | 773 | 834 | - |
| \$/GJ LHV | Capital (15% of TCR) | 5.20 | 5.26 | 4.60 | 4.96 | - |
| | O&M costs (4% of OC per year) | 1.19 | 1.21 | 1.06 | 1.14 | - |
| | Fuel (at 1.24 \$/GJ, LHV) | 2.17 | 2.18 | 2.17 | 2.15 | - |
| | Electricity revenue (4.72/6.38 c/kWh) | -0.64 | -0.87 | -0.60 | -0.63 | - |
| | Total hydrogen cost | 7.92 | 7.78 | 7.22 | 7.62 | - |
| | Extra \$/GJ for disposal at 5 \$/mt CO2 | 0.72 | 0.72 | 0.72 | 0.71 | - |

Results

Varying Electricity/H2 ratio




At constant S/C:
 $\Delta E/\Delta H = \sim 59.5\%$

With syngas cooler,
 can decrease S/C and
 get $\Delta E/\Delta H \sim 70\%$ at
 the expense of higher
CO2 emissions

Configurations with syngas cooler

trade-off between electricity and CO2 emissions



Conclusions

- ◆ The production of de-carbonized electricity or hydrogen from coal via oxygen-blown IGCC requires essentially the same plant configuration
- ◆ Such plant can operate with Electricity/H₂ ratios spanning the whole range from about zero to ∞
- ◆ De-carbonized H₂ can be traded off de-carbonized Electricity at an efficiency of $\sim 60\%$ for all configurations. In configurations with syngas cooler, efficiencies $\sim 70\%$ can be achieved at the expense of higher CO₂ emissions
- ◆ At CO₂ disposal costs of 5 \$/t CO₂, cost of de-carbonized H₂ is in the range 8.5-10 \$/GJ LHV
- ◆ Cost of avoided CO₂ from coal-to-H₂ plants can be as low as 5-10 \$/t CO₂. Then must add disposal cost


More Conclusions

- ◆ Energy efficiency advantage of syngas cooler configurations vanishes as ratio E/H_2 decreases
- ◆ The costs of current water-tube syngas cooler designs make them unattractive for electricity and (even more) for H_2 production
- ◆ Co-capture of CO_2 and H_2S appears to have the same cost of sulfur removal alone. If that's confirmed, co-capture allows capturing CO_2 at almost zero cost.
- ◆ Increasing gasification pressure from 70 to 120 bar does not seem to give significant advantages
- ◆ “Fuel-grade” H_2 vs pure H_2 increases electric efficiency by ~1 percentage point and decreases H_2 cost by ~4%

Assumptions

| | | | |
|--|-------|---|----------------|
| COAL HANDLING, GASIFIER and ASU | | STEAM CYCLE | |
| Power for coal handling, % of coal LHV | 1 | Steam evaporation pressures, bar | 165, 36, 15, 4 |
| Water/solids ratio in slurry | 0.333 | Steam temperature at admission, °C | 565 |
| Gasification pressure, bar | 70 | Condensation pressure, bar | 0.04 |
| Syngas temperature at gasifier exit, °C | 1327 | HRSG gas side pressure losses, kPa | 3 |
| Heat losses in gasifier, % of input LHV | 0.5 | Pinch point ΔT , °C | 8 |
| ASU power consumption, $\text{kJ}_{\text{el}}/\text{kg}_{\text{PURE O}_2}$ | 918.9 | Minimum ΔT in SH and RH, °C | 25 |
| O ₂ purity, % vol. | 95 | Deaerator pressure, bar | 1.4 |
| Pressure of O ₂ and N ₂ delivered by ASU, bar | 1.01 | Power for heat rejection, % of heat discharged | 1 |
| Pressure of O ₂ to gasifier, bar | 84 | Hydraulic efficiency of pumps, % | 0.75 |
| Temperature of O ₂ to gasifier, °C | 200 | Organic/electric efficiency of motor drives | 0.94 |
| QUENCH OR SYNGAS COOLER | | SULFUR REMOVAL (Physical Absorption) | |
| Pressure losses, % | 2 | Temperature of absorption tower, °C | 35 |
| Syngas loss (accounts for unconverted carbon), % | 0.8 | Syngas pressure loss, % | 1 |
| Ash discharge temperature (for syn-cooler), °C | 350 | Moles of CO ₂ removed per Mole of H ₂ S | 2 |
| Blowdown (for quench), % | 2 | Net steam consumption, MJ 5 bar steam /kgS | 5 |
| HEAT EXCHANGERS | | CO ₂ REMOVAL (Physical Absorption) | |
| Pressure loss, % | 2 | Temperature of absorption tower, °C | 35 |
| Minimum ΔT for gas-liquid heat transfer, °C | 10 | Syngas pressure loss, % | 1 |
| Pinch point ΔT for evaporators, °C | 8 | Pressure of last (4th) flash drum, bar | 1.05 |
| Heat losses, % of heat transferred | 0.7 | | |
| WATER-GAS SHIFT REACTORS | | SYNGAS EXPANDER/COMPRESSOR | |
| Pressure loss, % | 4 | Polytropic efficiency of syngas expander, % | 88 |
| Temperature at exit of HT reactor, °C | 400 | Polytropic efficiency of syngas compressor, % | 85 |
| Temperature at inlet of LT reactor, °C | 200 | Pressure of syngas to GT combustor pressure | 1.5 |
| | | CO ₂ COMPRESSOR | |
| | | Final delivery pressure, bar | 150 |
| | | Compressor adiabatic efficiency, % | 82 |
| | | Final pump efficiency, % | 75 |
| | | Temperature at inter-cooler exit, °C | 35 |
| | | Pressure drops inter-cooler and dryer, % | 1 |
| | | # of inter-coolers set maintain CO ₂ below 200°C | |

Electricity-Pure CO₂ capture-Syngas cooler



Other configurations

- ◆ Plants with no gas turbine give higher hydrogen production, but the significant reduction of electricity production makes them unattractive
- ◆ If fuel-grade (~93% pure) hydrogen is acceptable, H₂ production increases by 0.7 percentage point and hydrogen cost decreases by ~4%
- ◆ In schemes with syngas cooler, Electricity/H₂ ratio and overall efficiency can be increased, at the expense of higher CO₂ emissions, by lowering the steam/carbon ratio
- ◆ Increasing gasification pressure to 120 bar improves efficiency of configurations with quench, while those with syngas cooler are almost unaffected. Impact on hydrogen cost is marginal